


Lecture 22 - Biological Nitrogen Removal

Total N after secondary treatment $\approx$ 25-30 mg/L


Biological N removal can reduce to $\approx$ 5-8 mg/L

Nitrification: two-step process: (see M&E Fig 7-21, pg 2)

1. oxidation of ammonia, NH_4 , to nitrite, NO_2




2. oxidation of nitrite NO_2 to nitrate NO_3




Nitrification is slightly less thermodynamically favorable than oxidation with oxygen, but both can proceed in biological treatment such as AST

Nitrifying bacteria grow more slowly than heterotrophic bacteria and have lower cell yield — longer detention times needed to achieve nitrification in AST



1 gram N uses 4.57 grams O_2
based on stoichiometry

In actuality, less O_2 is needed, since O is generated by fixing CO_2 and N into cell mass. This uses [ALK]:



1 gram N uses 7.14 g ALK as CaCO_3





Figure by MIT OCW.

Adapted from: G. Tchobanoglous, F. L. Burton, and H. D. Stensel. *Wastewater Engineering: Treatment and Reuse*. 4th ed. Metcalf & Eddy Inc., New York, NY: McGraw-Hill, 2003, p. 617.

Both reactions actually contribute. Overall reaction is estimated as:




For each gram of N, 4.25 g O_2 used, 0.16 g new cells formed, 7.07 g Alk as CaCO_3 used

Denitrification


Bacteria oxidize organic substrate using nitrate/nitrite as electron acceptor

Nitrate goes as: $\text{NO}_3^- \rightarrow \text{NO}_2^- \rightarrow \text{NO} \rightarrow \text{N}_2\text{O} \rightarrow \text{N}_2$

Organic substrate may be wastewater:




Occurs under anoxic conditions in preanoxic process:



Sometimes called "substrate-driven" denitrification

Wastewater is electron donor



Postanoxic denitrification:



Called "endogenous driven"


Endogenous decay of cells supplies electron donors $\rightarrow$ slower rate of reaction, requires longer retention times

Sometimes supplementary source of carbon (electron donor) added = methanol or acetate




Conditions: $\text{DO} < 0.2 \text{ mg/L}$ in bulk liquid


Actual DO in floc can be less than bulk liquid and nitrification and denitrification may proceed simultaneously:



Other options include a "two-sludge" system:



Race-track oxidation ditch



Same in principle as preanoxic system

Rate processes

Reactions are represented in same general form:

$$\mu_g = \mu_{max} \frac{S}{S + K_s}$$

Coefficient values differ:

	μ_{max} $\left(\frac{g \text{ VSS}}{g \text{ VSS} \cdot d} \right)$	K_s $\left(\frac{g \text{ subst.}}{m^3} \right)$	Y $\left(\frac{g \text{ VSS}}{g \text{ subst.}} \right)$	Substrate
Heterotrophs	3-13	5-40	0.3-0.5	bCOD
Nitrification	0.2-0.9	0.5-1.0	0.1-0.15	NH_4-N
Denitrification	3.2	9	0.4	COD
w/ methanol	0.5-2	9-13	0.17	COD (methanol)

Lecture 20, Part 2 - Biological Phosphorus Removal

Phosphorus in wastewater treatment plant effluents is a concern because P is usually the limiting nutrient in fresh water bodies

P in effluent can therefore cause eutrophication of lakes and rivers

Typical P concentrations:

	Total P	Soluble P
Untreated domestic wastewater	10 mg/L	7 mg/L
After primary treatment	8	7
After secondary treatment	7	7

Typical removal in secondary biological treatment is 10 to 30 %

In water-quality limited streams, effluent limits for P are set at 0.1 to 2 mg/L

Phosphorus chemistry =

Phosphorus analytical chemistry is tricky because there are not analytical methods to quantify the forms of P important for biota

Ironically, P cycling through organisms is well understood because there are radioactive isotopes of P that can be used as tracers

Analytically determined P forms:

Total P (TP)

Particulate P - trapped by 0.45- μ m filter

Soluble P - passes thru' filter

Soluble reactive P - measured by molybdate blue method (without acid digestion) = ortho-P

Soluble unreactive P - remainder

Forms of phosphorus available to microorganisms:

soluble reactive P

= orthophosphate PO_4^{3-}

Polyphosphates from detergents are also a concern:

e.g. sodium tripolyphosphate $\text{Na}_5\text{P}_3\text{O}_{10}$

Boil in

H_2SO_4 for

90 min.

Acid digestion of sample causes polyphosphates

to break down to orthophosphates - then

measure with molybdate blue method to get

Total inorganic P = ortho-P + polyphosphate

In environment, polyphosphates hydrolyze to form ortho-P over time

Strong acid digestion (nitric or perchloric acid)

of unfiltered sample breaks down organic

particulates to ortho-P - then measure

with molybdate blue to get Total P =

Total inorganic P + organic P

Summary:

No digestion - ortho-P

H_2SO_4 acid digestion - Inorganic P = ortho-P
+ poly-P

strong acid digestion - Total P = inorganic P
+ organic P

Above can be done on filtrate of 0.45- μm
filter to get soluble fraction or on
unfiltered sample to get totals

Biological P removal systems are designed to create conditions favorable to Phosphorus Accumulating Organisms (PAOs)

Certain bacteria (e.g. *Acinetobacter*) synthesize polyphosphates and store it in their cellular material - process is sometimes called "luxury uptake"

PAOs are favored by alternating aerobic/anaerobic conditions
First step is anaerobic:

Available carbon and electrons are stored in polyhydroxybutyrate (PHB) and other volatile fatty acids. This storage is not done if electron acceptors like O_2 or NO_3 are present, hence the need for anaerobic conditions. Simultaneously, polyphosphate is broken down and ortho-P is released to mixed liquor (see Figure 7-23 from M+E, pg 4)

Next step is aerobic or anoxic (denitrifying):
Bacteria metabolize stored PHB, uptake ortho-P, stored as poly-P within cell material. Cells become enriched in polyphosphates

Last step is removal of P-enriched cells in wasted sludge - P is removed along with cells.

Key to success of P removal is encouraging the growth of the particular types of bacteria that accumulate P.

The anaerobic reactor causes fermentation that breaks down COD to acetate, a substrate preferred by PAOs. This step is sometimes called the "selector" since it favors (selects for) PAOs.





Figure by MIT OCW.


Adapted from: Rittman, Bruce E., and Perry L. McCarty. *Environmental Biotechnology: Principles and Applications*. New York, NY: McGraw-Hill, 2001.



Typical profile of soluble phosphorus concentrations in a biological nutrient removal process (ATP = adenosine triphosphate, ADP = adenosine diphosphate).

Figure by MIT OCW.

Adapted from: Rittman, Bruce E., and Perry L. McCarty. *Environmental Biotechnology: Principles and Applications*. New York, NY: McGraw-Hill, 2001.




Fate of soluble BOD and phosphorus in nutrient removal reactor.

Figure by MIT OCW.


Adapted from: G. Tchobanoglous, F. L. Burton, and H. D. Stensel. *Wastewater Engineering: Treatment and Reuse*. 4th ed. Metcalf & Eddy Inc., New York, NY: McGraw-Hill, 2003, p. 626.

Configurations for biological P removal

Pre-denitrification: (also called A²O process)




Bardenpho process:



Removes 93% total N, 65% total P

PhoStrip process =



Hydrolysis in anaerobic reactor releases poly-P to water (supernatant) — 30-70 mg P/L

Addition of lime to precipitator tank raises pH to ~11, causes $\text{Ca}_3(\text{PO}_4)_2$ (s) to precipitate

Requires more sophisticated operation than alternatives above


Most effective P removal is through Chemically Enhanced Primary Treatment (CEPT) — discussed in later lecture

Sequencing batch reactor (SBR)


Rather than continuous flow through sequence of tanks for different treatment steps, all steps are done sequentially in a single tank

For conventional AST:


Step 1 - Fill
(add substrate)




Step 2 - React




Step 3 - Settle



Step 4 - Draw
(decant effluent)



Step 5 - Idle
(waste sludge)



SBRs are very flexible as to steps, making it possible to add anoxic and anaerobic steps to the sequence for N or P removal

SBR for P removal

Step 1 - Fill

Step 2 - Anaerobic react
(tank is mixed but without aeration)

Step 3 - Aerobic react

Step 4 - Anoxic react (denitrification)

(Note: steps 3 and 4 may be repeated)

Step 5 - Settle

Step 6 - Decant

Step 7 - Idle (waste sludge)

SBR WITH BIOLOGICAL PHOSPHORUS REMOVAL




Figure by MIT OCW.

Adapted from: G. Tchobanoglous, F. L. Burton, and H. D. Stensel. *Wastewater Engineering: Treatment and Reuse*. 4th ed. Metcalf & Eddy Inc., New York, NY: McGraw-Hill, 2003, p. 813.