

Real Options for Geothermal Energy

Lightning Dock Expansion

Chad Holmes
IDS.330 Spring 2021



Cautionary Statement

The work presented here was completed by the author as an academic exercise in partial fulfillment of the requirements for MIT course IDS.330 and are not endorsed by any professional company, organization, or working group.


Information included in the models is based on publicly available data. Model inputs were determined from primary sources or selected as a best educated guess by the author when no suitable information source could be identified.

Although referenced directly in the report, neither Cyrq Energy nor Climeon was directly consulted on the content. Conclusions drawn within this report should not be considered a professional recommendation, but simply a hypothetical analysis for the purposes of educational training.

Lightning Dock History

- 1948 – Agricultural well struck boiling water at 26.5 m depth
- 1977 – AMAX Exploration drilled 58 wells as part of an exploration campaign.
- 1977 – Burgett Geothermal Greenhouses, Inc. began operating with direct use of geothermal waters.
- 1982 – Burgett installed 40 kW and 100 kW plants, which failed after installation. Tried again with other designs in 1995 and 2008.
- 1986 – Lightning Dock Geothermal, Inc. obtained lease to develop a power plant.**
- 2013 – Cyrq Energy (post-acquisition) brought 4 MW plant online and formed a power purchase agreement (PPA) with Public Services of New Mexico (PNM).**
- 2018 – Turboden repowered Lightning Dock, increasing commercial capacity to 10 MW.**


Lightning Dock KGRA:
Hidalgo County, New Mexico



From Fig 1 in (Crowell and Crowell, 2014)

© Geothermal Rising. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <https://ocw.mit.edu/help/faq-fair-use/>

Geothermal in NM: Renewable Portfolio Standard (RPS)



Click below to search the NMPRC website

New Mexico Public Regulation Commission and Renewable Energy in New Mexico

The [Public Regulation Commission](#) reviews and approves renewable energy procurement plans and reports of [Investor Owned Utilities](#) ("IOU's") and [Rural Electric Cooperatives](#) ("Coops") pursuant to the [Renewable Energy Act \("REA"\)](#), §§ 62-16-1 et seq. NMSA 1978 and [Title 17.9.572 NMAC](#) ("Rule 572"). IOU's in New Mexico are procuring renewable energy and renewable energy certificates from New Mexico renewable generation facilities to meet the Renewable Portfolio Standard (RPS) requirements of the REA and Rule 572.

Investor Owned Utilities and the RPS

The REA and Rule 572 established an RPS applicable to all investor owned electric utilities in New Mexico. In 2006, the RPS will be 5% of retail sales in [kWh's](#), reaching 10% by the year 2011. Recent legislative changes to the REA ([SB418](#), signed March 5, 2007 by Governor Bill Richardson) have increased the RPS percentages and extended the time lines - IOU's now must have in their portfolio as a percentage of total retail sales to New Mexico customers, renewable energy of no less than 15% (by 2015) and 20% (by 2020).

Resource Diversity and the RPS

In addition to the RPS, Rule 572 requires within the total portfolio percentage renewable energy portfolio as follows: Diversity requirements for IOU's as % of

No less than 30% Wind

No less than 20% Solar

No less than 5% Other technologies

No less than 1.5% Distributed Generation (2011-2014) and 3% Distributed Generation by 2015

No less than 30% Wind
No less than 20% Solar
No less than 5% Other technologies

<http://www.nmprc.state.nm.us/utilities/renewable-energy.html>

Source: public domain. Used with permission.



Geothermal energy uses heat from below the earth's crust to create steam that turns the turbine, ultimately generating electricity. Like wind and solar, geothermal energy emits no pollutants into the air; unlike wind and solar energy, it is available to serve customers around the clock.

PNM is the first customer to take energy from the Lightning Dock Geothermal Plant.

<https://www.pnm.com/geothermal>

© PNM. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <https://ocw.mit.edu/help/faq-fair-use/>

Enhanced Geothermal Systems (EGS)




Figure 3.2 in (Tester and Herzog, 1990)

© MIT. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <https://ocw.mit.edu/help/faq-fair-use/>
IDS.330 Final Project




Conventional

Unconventional

EGS

..... **Natural Geothermal Systems**




To generate power from natural geothermal systems you need:

 +
  +
 

Abundant heat found in rocks at depth Fluid to carry heat from the rocks Small pathways to conduct fluid through the hot rocks





..... **Problem**

Despite the presence of heat, sometimes conditions are not ideal for power generation from natural geothermal systems. In these cases you have:

 +
  +
 

Abundant heat found in rocks at depth Insufficient fluid to carry the heat Limited pathways to conduct fluid


A man-made enhanced geothermal system (EGS) can extract the abundant heat resource tens of thousands of feet below the surface and put it to good use. This would require:

 =
  +
  +
 

What makes EGS? An abundant, previously-stranded, heat source Fluid injected from the surface Permeable pathways enhanced by injected fluids

Infographic from U.S. Dept of Energy: energy.gov/sites/default/files/2015/04/f22/EGS%20Infographic_0.pdf Source: public domain. Used with permission.

Binary Cycle Power Plants



- Primary fluid produced from the subsurface.
- Heat exchange between primary and secondary fluid with a low boiling point.
- Secondary fluid flashes to vapor and drives the turbines.
- Typically used for moderate to low temperature geothermal ($\leq 180^{\circ}\text{C}$).

Image from U.S. Dept of Energy
energy.gov/eere/geothermal/electricity-generation

Source: public domain. Used with permission.

Modular Concepts

- Climeon offers a compact binary cycle geothermal unit (HP150).
- Units cluster to form a Power Block.
- Power Blocks can be independently installed to build a larger-capacity aggregate facility.



Image from https://climeon.com/geothermal_plants

© MIT. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <https://ocw.mit.edu/help/faq-fair-use/>



Deterministic Case






- Excel-based model for NPV calculation
- NPV (discount rate = 9%) components:
 - **Income** = electricity generated times PPA pricing (kWh*\$ /kWh)
 - **CAPEX** = wells + power plant + fluid distribution + stimulation + exploration
 - **OPEX** = power plant O&M + field O&M + water O&M + labor
- Assumes a **30-year life span**
- Assumes a **50% above wholesale electricity price** for power purchase agreement (PPA)
 - Similar to current value of Cyrq/PNM PPA
 - Can be easily adjusted on cover sheet with alternate values

Deterministic Model		Case Study: Lightning Dock, NM					
RESOURCE	VALUE	UNITS	REFERENCE	NOTES			
Surface Temperature (2020)	15.8	degrees C	Dahal, 2012				
Average Geothermal Gradient	100	degrees C / km	Crowell, 2014; can be h	based on hole TG 56-14, 4 km SW of anomaly			
Average Well Depth (near vertical, MD)	1.1	km		calculated based on reservoir temperature			
Initial Average Reservoir Temperature	125	degrees C		stick to temperature profile of Climeon (max: 120 C)			
Production Well Temperature Loss	5	degrees C	Beckers, 2013; GETEM	aggressive value. Beckers uses 10deg w/ 5km well. GETEM calculates <2			
Production Temperature (at well head)	120	degrees C		re-compute with equation from Beckers, 2016 once other variables defined			
Water Loss Rate	2%	% of injected water	SAM	for open loop			
Production Flow Rate per Well Pair	35	kg/s	GETEM, NREL	https://atb.nrel.gov/electricity/2020/index.php?=>			
CAPEX (per module)	VALUE	UNITS	REFERENCE	NOTES			
Drilling & Completions Costs	\$ 1,305,956.16	USD (1 well)	Beckers 2013	Lukawski, 2016			
Wells per module	2	well count per unit		doublet			
Surface Plant Costs	\$ 1,000.00	\$/kWe	Beckers 2013	waiting on reply from Baseload Cap., stick with this for now			
Reservoir Stimulation per injection well	\$ 1,250,000.00	USD	Lowry, 2017	\$1,250,000 per injector stimulation, recent ballpark figure so no cost adjust			
Fluid Distribution Costs	\$ 279,300.00	USD	Beckers 2013	also ballpark figure, needs additional study based on New Mexico for more			
Redevelopment Factor	0.85		pers. conversation, Pres	could be cheaper to redrill than drill from scratch			
Thermal Drawdown Threshold	13.0	degrees C	GETEM	0.21Ti-12.2			
Thermal Drawdown Rate	0.5%		GETEM	varies from author-to-author (up to 4%)			
Redevelop Every	24	years					
Exploration Success Rate	100.0%			assumed 100% since area is already developed, normally ~20% (Glassley			
Total Capital Costs (exploration)	\$ 2,133,542.54	USD	Beckers 2016	Ccap = Ccap,well + Ccap,pp + Ccap,stim + Ccap,distr + Ccap,expl			
Total Capital Costs (drilling)	\$ 2,611,912.33	USD	Beckers 2016				
Total Capital Costs (non-drilling)	\$ 3,121,310.00	USD	Beckers 2016				
POWER PLANT (modules)	VALUE	UNITS	REFERENCE	NOTES			
Plant Type	Binary ORC			governs system physics			
Plant Useful Life	30	years	Augustine, 2009	basis for cost analysis			
Heat Inlet Temperature	120	degrees C		simplifying assumption, ignoring secondary fluid heat exchange			
Cool Inlet Temperature	50	degrees C		backing out from known Climeon Mwe			
Heat Capacity	2.28	kJ/kg-K	Dincer, 2010	isobutane, not sure if this is their fluid			
Temperature Drop	70.0	degrees C (or K)					
Enthalpy Drop	5.6	MWh		Q = q x Cp X delta T			
Capacity Factor	95%		Glassly 2015, GETEM				
Degradation Factor	0.5%		NREL, 2002	using 0.5% NREL degradation per year			
Generation Efficiency (2nd Law Efficiency)	0.3		Beckers 2019, Glassly	relates power production (Mwe) to exergy of geothermal fluid			
Avg Net Power Output per Unit	1.59	MWe		slightly high compared to Climeon ratings, but will degrade based on C51f			
OPEX	VALUE	UNITS	REFERENCE	NOTES			
Labor (per module)	\$ 386,838.52	USD	GETEM				
Power Plant Ops & Maintenance (per module)	\$ 314,009.04	USD	Beckers 2013	0.75*Clabor + 0.015*Ccp			
Field Ops & Maintenance (per module)	\$ 122,828.75	USD	Beckers 2013	0.25*Clabor + 0.01*Cwell; assume this includes pump costs			
Water Ops & Maintenance	\$ 5,481.02	USD	GETEM	water loss: \$300/acre-ft			
Total Annual O&M costs (per module)	\$ 442,318.81	USD		sum of OMpp+OMfield+OMwater			
FACTORS/INDICES	VALUE	UNITS	REFERENCE	NOTES			
Price Index from for Q4 2004 to 2020 USD	143%		UCCI (IHS)				
Price Index from for Q4 2009 to 2020 USD	104%		UCCI (IHS)				
Price Index from for Q4 2012 to 2020 USD	107%		UCCI (IHS)				
Employment Cost Index (Utilities) compared to 2004	145%		BLS	https://www.bls.gov/news.release/eci.t02.htm			
Discount rate	9%		Sanyal 2007	variable to change for sensitivity study			
Learning rate	6%		Lukawski 2014	only using well cost learning rate from this paper (others also listed)			
Contract rate above wholesale	50%		PNM, 2014				
Learning rate exponent	-0.089						
Calendar Year	2020		2021	2022	2023	2024	2025
Nominal Year	0		1	2	3	4	5
Calculated Price	0.086	0.000		0.000	0.000	0.000	0.000
Price (\$/kWh)	0.086			0.090	0.090	0.090	0.090
Capacity Level Increase (Input)							
Unit Count				5	5	5	5
Total Capacity Increase (kWh)	13946008	55784030		0	0	0	0
Total Undegraded Capacity (kWh)	0	13946008	69730038	69730038	69730038	69730038	69730038
Thermal Decline (deg C)	120	119	119	118	117	116	115
Thermal Decline Degradation (kWh)	0	119537	1192384	1784108	2372873	2958695	3544517
Power Plant Degradation Factor	1.000	1.000	0.995	0.990	0.985	0.980	0.975
Total Overall Capacity (kWh)	0	13826470	68194966	67268170	66351851	65445899	64541447
Revenue	\$0.00	\$1,240,234.39	\$6,117,088.46	\$6,033,954.81	\$5,951,761.00	\$5,870,497.10	\$5,790,243.20
CAPEX (Drilling)	\$2,611,912.33	\$9,049,475.21	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00
CAPEX (Redevelopment)	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00
CAPEX (Other)	\$5,254,852.54	\$12,485,240.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00
OPEX	\$0.00	\$442,318.81	\$2,211,594.06	\$2,211,594.06	\$2,211,594.06	\$2,211,594.06	\$2,211,594.06
Cashflow	\$0.00	(\$20,736,799.63)	\$3,905,494.40	\$3,822,360.76	\$3,740,166.95	\$3,658,903.04	\$3,578,639.13
DCF	\$0.00	(\$19,024,586.81)	\$3,287,176.50	\$2,951,563.83	\$2,649,628.56	\$2,378,035.93	\$2,138,563.00
Present value of cashflow	\$11,687,244						
Up-front investment	\$7,866,765						

Net present value: \$3.8MM

Key Uncertainties




Probability density functions (pdfs) for value sampling



Sensitivity testing to determine variable importances for the model results

Electricity Price

- Price step change inserted on a random date (uniform selection) and magnitude sampled from PDF
- Volatility added by sampling from normal distribution determined from forecast and confidence intervals.



Base Case

NO FLEXIBILITY

Uncertainties



- Drilling & completions costs
- Pricing (future step change)
- Thermal drawdown rate
- Geothermal gradient

Flexibilities

- None

Base Case Statistics	N=2000
ENPV	-\$4.0MM
STD(NPV)	\$8.7MM
P05 NPV	-\$19.8MM
P50 NPV	-\$2.3MM
P95 NPV	\$6.6MM
% Difference from NPV _{Det}	-207%

IDS.330 Final Project



Redevelop Only

REDRILL

Uncertainties



- Same as Base Case

Flexibilities

- Redrill after 13°C thermal drawdown. Temperature gets reset for primary fluid entering plant.

Redevelop Only Statistics	N=2000
ENPV	-\$1.8MM
STD(NPV)	\$6.5MM
P05 NPV	-\$14.3MM
P50 NPV	-\$0.7MM
P95 NPV	\$6.5MM
% Difference from NPV _{Det}	-150%

IDS.330 Final Project



Redevelop and Grow

Uncertainties

- Same as Base Case



REDRILL
BUILD

Flexibilities

- Redrill after 13°C drawdown.
- Increase capacity 25% if prices up $\geq 20\%$ compared to time of PPA signing.
- PPA rate “renegotiated” with each capacity increase.

Redevelop Grow Statistics	N=2000
ENPV	\$9.7MM
STD(NPV)	\$10.3MM
P05 NPV	-\$6.6MM
P50 NPV	\$9.4MM
P95 NPV	\$27.0MM
% Difference from NPV _{Det}	162%

IDS.330 Final Project



Full Flexibility

Uncertainties

- Same as Base Case



Flexibilities

- Redrill after 13°C drawdown.
- Increase capacity 25% if prices up $\geq 20\%$ compared to time of PPA signing.
- Shut down 25% of modules if prices suddenly drop by $\geq 20\%$.

**REDRILL
BUILD
SHRINK**


Full Flexibility Statistics	N=2000
ENPV	\$8.2MM
STD(NPV)	\$10.3MM
P05 NPV	-\$8.8MM
P50 NPV	\$8.1MM
P95 NPV	\$25.2MM
% Difference from NPV _{Det}	121%

IDS.330 Final Project



Key Insights

- **Redevelop and Grow** case **dominates** all other scenarios.
Best model.
- **Full Flexibility** less **attractive** likely due to the loss of income as modules taken offline.





Sensitivity Test for Full Flexibility Case

- Increasing **reduction amount** (RA) leads to greater downside risk and lower ENPV.
- Redevelop and Grow scenario is the natural limit as $RF \rightarrow 0$.

General Parameters

Contract rate over wholesale	50%
Drilling learning rate	6%
Discount rate	9%
Price trigger for flexibility	20%
Expansion amount	25%
Reduction amount	50%





Sensitivity Test for Full Flexibility Case

- Decreasing **reduction amount (RA)** reveals a window where downside risk is lower and ENPV is maximized.
- Full Flexibility with RA=10% is the preferred model.**

General Parameters

Contract rate over wholesale	50%
Drilling learning rate	6%
Discount rate	9%
Price trigger for flexibility	20%
Expansion amount	25%
Reduction amount	10%



RESULTS REVERSAL! →

Learnings and Recommendation

- **Deterministic model overpredicts NPV** compared to the Base Case Monte Carlo model (Flaw of Averages). The deterministic predicted profit nearly matches the Base Case predicted loss.
- **Base Case scenario has significant downside** with >60% of modeled realizations ending in losses.
- **Redevelop Only scenario limits downside risk.** ~56% of model realizations still result in a net loss, but the losses are not as extreme as in the Base Case.
- **Redevelop and Grow scenario significantly improves upside capture** by increasing capacity and renegotiating PPAs when electricity prices surge. Also **reduces downside risk** and has an ENPV of just under \$10MM.
- **Full Flexibility** scenario performs worse than Redevelop and Grow when 25%+ of existing power plant modules are shut down in response to a downturn in electricity prices. **10% reduction produces the recommended model** with twice the ENPV of the deterministic case and the least downside risk among all scenarios. This model correctly **balances cost savings of lower O&M expenses with income loss from reduced capacity.**

MIT OpenCourseWare
<https://ocw.mit.edu/>

IDS.333 Risk and Decision Analysis
Fall 2021

For information about citing these materials or our Terms of Use, visit: <https://ocw.mit.edu/terms>.